

## **ADDENDUM NO. 1**

Include this Addendum as part of the Contract Documents. It supplements portions of the original Drawings and Specifications (on drawings only), the intent of which shall remain, except as revised herein:

No manual was issued with the bid documents; therefore, this is a response to questions asked by potential bidders for clarification.

### **CONTRACTOR'S INSURANCES AND BONDS:**

- 1-1 COMMERCIAL GENERAL LIABILITY - Commercial General Liability insurance for the Project written on an occurrence form with policy limit of not less than one million dollars (\$1,000,000) each occurrence, five million dollars (\$5,000,000) general aggregate.
- 1-2 AUTOMOBILE LIABILITY - Automobile Liability covering vehicles owned and non-owned vehicles use, by the Contractor, with policy limits of not less than one million dollars (\$1,000,000) per accident. Worker's Compensation at statutory limits.
- 1-3 PERFORMANCE BOND - The Contractor shall provide (simultaneously with executed contract) surety bonds, from a company or companies lawfully authorized to issue surety bonds in the jurisdiction where the Project is located and one to which the Owner has no reasonable objection to. The Contractor shall furnish a Bond covering the faithful performance of the Contract and the payment of all obligations arising thereunder in the amount of 100 percent of the Contract Sum. The premiums shall be paid by the Contractor.

### **SCHEDULING RESTRICTIONS ASSOCIATED WITH BRIDGE AND ABUTMENTS CONTRACT:**

- 1-4 Wyoming County Highway Department is planned to begin abutment and bridge work in September. Bridge delivery will be coordinated for the same time once the abutments are finished. This contract work will precede the abutment construction and bridge erection work.

### **BOARDWALK COLUMN FOUNDATION PAYMENT:**

- 1-5 Base bid shall assume three (3) foot (by design diameter) excavation to solid / stable bearing material (refer to geotechnical report prepared by Foundation Design).
- 1-6 Contractor shall provide a unit price (cubic yards) for reduced or additional excavation and disposal required to reach solid / stable bearing material. This unit price may assume performing excavation with manpower and equipment anticipated to perform this work. Should the contractor experience conditions that requires mechanical equipment not anticipated, the Village will negotiate a unit price to perform the work.
- 1-7 Final basis of payment will be quantity of material (cubic yards) times the unit price.

**ADDENDUM NO. 1**

**MATERIALS:**

- 1-8 COMPOSITE DECKING – Preferred brands for composite decking include: Trex, Azek, or approved equal.
- 1-9 STONE DUST – Material shall consist of crushed limestone and meet DOT spec ITEM 304.01940004 – “TRAILWAY TOP COURSE, STONE DUST”.

**ATTACHMENTS:**

- 1-10 Statement of Special Inspections
- 1-11 Project Geotechnical Evaluation

END OF ADDENDUM

Contractor acknowledges receipt and review of Addendum No. 1 dated May 16, 2022:

*Contractor Signature:* \_\_\_\_\_ *date:* \_\_\_\_\_